

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Battery inverter/charger

Name and address of the applicant

Victron Energy B.V.
De Paal 35, 1351 JG Almere
Netherlands

Name and address of the manufacturer

Victron Energy B.V.
De Paal 35, 1351 JG Almere
Netherlands

Name and address of the factory

See page 3

Note: When more than one factory, please report on page 2

 Additional Information on page 2

Ratings and principal characteristics

MultiPlus-II 24/3000/70-32, Multiplus-II 24/3000/70-32 GX:
DC input (discharge): 24Vdcnom, 19-33Vdc, 125A max
DC output (charge): 24Vdc, 70A
AC in: 187-250Vac, 32A, 50/60Hz
AC out: 230Vac, 11A, 50/60HzMultiPlus-II 48/3000/35-32, MultiGrid-II 48/3000/35-32, MultiPlus-II 48/3000/35-32 GX:
DC input (discharge): 48Vdc nom., 38-66Vdc, 75A max
DC output (charge): 48Vdc, 35A max
AC in: 187-250Vac, 32A, 50/60Hz
AC out: 230Vac, 11A, 50/60HzMultiPlus-II 48/5000/70-50, MultiGrid-II 48/5000/70-50, MultiPlus-II 48/5000/70-50 GX:
DC input (discharge): 48Vdc nom., 38-66Vdc, 110A max
DC output (charge): 48Vdc, 70A max
AC in: 187-250Vac, 50A, 50/60Hz
AC out: 230Vac, 19A, 50/60Hz

Trademark / Brand (if any)

Victron Energy

This CB Test Certificate is issued by the National Certification Body

Kiwa Nederland B.V.
Wilmersdorf 50, Apeldoorn, 7327, Netherlands*Raphael Rader*Digitally signed | see <http://ca.kiwa-deutschland.de> for more details

Signature: Raphael Rader

Date: 2022-10-10

page 1 of 3

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

MultiPlus-II 24/3000/70-32,
Multiplus-II 24/3000/70-32 GX
MultiPlus-II 48/3000/35-32, MultiGrid-II 48/3000/35-32
MultiPlus-II 48/3000/35-32 GX
MultiPlus-II 48/5000/70-50, MultiGrid-II 48/5000/70-50
MultiPlus-II 48/5000/70-50 GX

Additional information (if necessary may also be reported on page 2)

Additional Information on page 2

A sample of the product was tested and found to be in conformity with

IEC 60335-1:2010, IEC 60335-1:2010/AMD1:2013, IEC 60335-1:2010/AMD2:2016, IEC 60335-2-29:2016, IEC 60335-2-29:2016/AMD1:2019

As shown in the Test Report Ref. No. which forms part of this Certificate

17PP264-33_0

This CB Test Certificate is issued by the National Certification Body

Kiwa Nederland B.V.
Wilmersdorf 50, Apeldoorn, 7327, Netherlands



Raphael Rader

Digitally signed | see <http://ca.kiwa-deutschland.de> for more details

Signature: Raphael Rader

Date: 2022-10-10

page 2 of 3